

**DRINKING WATER AND SANITATION DIVISION, KHUNTI
DISTRICT LEVEL WATER TESTING LABORATORY**

WATER TEST REPORT

DATE :- 02/03/2020

CUSTOMER NAME :-

SOURCE OF THE SAMPLE :- F/W

BLOCK :- KHUNTI GP :- BIARHU VILLAGE :- ERANDA TOLA :- TUTTOLI

PHYSICAL LOCATION :- KENDRIYA VIDYALAYA (Khunti) SAMPLE COLLECTED BY :- School

SL. NO	TESTED PARAMETERS	UNIT	BIS DESIRABLE LIMIT	BIS PERMISSIBLE LIMIT	ACTUAL LEVEL
1	IRON	Mg/l	0.3	1.0	B.D.I
2	FLUORIDE	Mg/l	1.0	1.5	—
3	CHLORIDE	Mg/l	250	1000	100
4	T.D.S	Mg/l	500	2000	65
5	ALKALINITY	Mg/l	200	600	100
6	TURBIDITY	NTU	1.0	5.0	—
7	HARDNESS	Mg/l	300	600	90
8	ph		6.5	8.5	7.2
9	NITRATE	Mg/l	45	45	—

REMARKS :- As per the above parameters analyzed, water sample is accepted for drinking purpose.

[Signature]
2-03-2020

CHEMIST
District water testing
Laboratory, Khunti

[Signature]
02/03/2020

J.E
District water testing
Laboratory, Khunti

[Signature]
02/03/2020

A.E
DW&SD, Khunti
Sub Division Urban, Khunti